



Product Certification Body accredited by  
Slovak national accreditation service

NOTIFIED BODY No. 1396  
Osloboditeľov 282, 059 35 Batizovce, Slovakia  
tel. +421 52 7752298 fax. +421 52 7881412 http://www.fires.sk



## EC – CERTIFICATE OF CONFORMITY

**1396 – CPD – 0064**

In compliance the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the Construction Products Directive – (CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### **Smoke and heat exhaust ventilator louver type, type OPTIMA**

used as a dual purpose ventilator (smoke and heat exhaust ventilator which has provision to allow its use for day to day ventilation) or ventilator without function of daily ventilation in accordance with EN 12101-2: 2003. Product properties are described in detail in the Initial type-testing report No. C1396/12/0008/4203/SC, issued by FIRES s.r.o., Notified Body 1396, on 21<sup>st</sup> November 2012;

placed on the market by

**Brakel Aluminium B.V.. Linie 48, 5405 AN UDEN, Netherlands**

and produced in the factory

**Brakel Aluminium B.V.. Linie 48, 5405 AN UDEN, Netherlands**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body - FIRES, s.r.o. - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in the Annex ZA of the standard

**EN 12101 - 2: 2003**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on the 21<sup>st</sup> November 2012 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Batizovce, 21<sup>st</sup> November 2012



Ing. Mária Gašperová  
Head of Product Certification Body

051468 FIRES 136/C-14/06/2012-E